



CERTIFICATE OF REGISTRATION

This is to certify that

Ideal Special Products FZC

P.O. Box 9033
Ajman Free Zone Gate No. 4
Ajman
United Arab Emirates

Meets the requirements of the BM TRADA **Q-Mark International Fire Door Manufacture** scheme to **STD 096 Region 2** which only operates in Armenia, Azerbaijan, Bahrain, Belarus, Georgia, Jordan, Kazakhstan, Kuwait, Oman, Qatar, Saudi Arabia, The United Arab Emirates, Turkey, Turkmenistan and Uzbekistan for the products on the attached schedule

Steve Roberts
Product Certification Operations Manager
For and on behalf of BM TRADA

Certificate Number

105

Date of Initial Certification

28 April 2010

Date of last issue

4 March 2022

Date of Expiry

27 April 2027

BM TRADA is a trading name of Warringtonfire Testing and Certification Limited, Chiltern House, Stocking Lane, High Wycombe, Buckinghamshire, HP14 4ND, UK
Registered Office: Warringtonfire Testing and Certification Limited, 3rd Floor, Davidson Building, 5 Southampton Street, London, WC2E 7HA, UK
Page 1 of 2
Reg No. 11371436.

This certificate remains the property of Warringtonfire Testing and Certification Limited. This certificate and all copies or reproductions of the certificate shall be returned to Warringtonfire Testing and Certification Limited or destroyed if requested. Further clarification regarding the scope of this certificate and verification of the certificate is available through BM TRADA or at the above address or at www.bmtrada.com

Registration Schedule

Establishment

Ideal Special Products FZC

Address

P.O. Box 9033
Ajman Free Zone Gate No. 4
Ajman
United Arab Emirates

Scope

Primary Field of Application (FoA) Reports (owned by this certified company)

Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	Rev	Owned by Certified Company named on this scope	Doorset Description	Rating	Test Type
-	-	-	-	-	-

Primary Field of Application (FoA) Reports (owned by and cascaded by a System Supplier)

The revision status of each FoA can be verified on the BM TRADA website under each System Supplier's certification entry.

Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	System Supplier owner of FoA Report	Doorset Description	Rating	Test Type
-	-	-	-	-

Test Reports

Test reports cannot be used in conjunction with any primary FoA reports. They must be followed precisely without any deviation whatsoever.

No specification or parameter changes are allowed at all from that stated within the test report such as size, shape, design, glazing, leaf/frame specification, hardware etc.

Test Report	Owner of Test Report	Doorset Description	Rating	Test Type
Chilt/RF07112 Doorset B	Ideal Special Products FZC	Ideal Special Products – 120 (Unglazed only)	120min	BS 476 Pt22
Chilt/12116	Ideal Special Products FZC	Ideal-90 (Doorset A) Unglazed	90min	BS 476 Pt22
		Ideal-60 (Doorset B) Unglazed	60min	BS 476 Pt22
BMT/FEP/F14232	Ideal Special Products FZC	IDEAL- Single Door – 90 (Doorset A) Unglazed	90min	BS 476 Pt22
		IDEAL- Double Door – 60 (Doorset B) Unglazed	60min	BS 476 Pt22
BMT/FEP/F14307 Rev. A	Ideal Special Products FZC	IDEAL- Double Door – 120 (Doorset A) Unglazed	120min	BS 476 Pt22
		IDEAL- Single Door – 120 (Doorset B) Unglazed	120min	BS 476 Pt22
WF370736	Ideal Special Products FZC	IDEAL- Single Door – 90 (Doorset A) With vision panel	90min	BS 476 Pt22
		IDEAL- Single Door – 90 (Doorset B) Unglazed	90min	BS 476 Pt22
WF372759 A	Ideal Special Products FZC	IDEAL- Single Door – 60 (Doorset A) With Vision Panel	60min	BS 476 Pt22
WF372759 B	Ideal Special Products FZC	IDEAL- Single Door – 60 (Doorset B) Unglazed	60min	BS 476 Pt22
WF372762 A	Ideal Special Products FZC	IDEAL- Single Door – 120 (Doorset A) With Vision Panel	120min	BS 476 Pt22
WF372762 B	Ideal Special Products FZC	IDEAL- Single Door – 60 (Doorset B) Unglazed	60min	BS 476 Pt22
WF372754	Ideal Special Products FZC	IDEAL- Double Door – 90 With Vision Panel	90min	BS 476 Pt22