



BMTV

CERTIFICATE OF PRODUCT VERIFICATION

This is to certify that

Ideal Special Products FZC

P.O. Box 9033
Ajman Free Zone Gate 4,
Ajman
United Arab Emirates.

Meets the requirements of the BMTV **Product Verification** Fire Door
Manufacture scheme to STD 01 for **the products on the attached schedule**

Compliance officer
BM TRADA VENTURES LLC

Certificate number: 030

Issue no: 2024 - 02

Certificate effective date: 17 May 2024

Certificate expiry date: 10 May 2029

Date of initial certification: 10 May 2024



eIACI BMTV

مركز الإمارات العالمي للاعتماد
Emirates International Accreditation Centre
CB-PRD-009

BMTV, Unit 904 Business Avenue Building, Deira, Dubai, United Arab Emirates

This certificate remains the property of BMTV. This certificate and all copies or reproductions of the certificate shall be returned to BMTV or destroyed if requested. Further clarification regarding the scope of this certificate and verification of the certificate is available through BMTV at the above address or at www.bmt-ventures.com

This certificate remains unauthenticated without the SEAL of AUTHENTICATION on the signature

Registration Schedule

Establishment

Ideal Special Products FZC

Address

P.O. Box 9033
Ajman Free Zone Gate 4,
Ajman
United Arab Emirates.

Scope

Primary Field of Application (FoA) Reports (owned by this certified company)

Primary FoA reports owned by this PV certified company are listed on the PV-Mark certificate along with the latest revision status. They are either used in isolation or can be used in conjunction with an appropriate associated document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	Rev	Owned by Certified Company named on this scope	Doorset Description	Rating	Test Type
		NA			

Primary Field of Application Reports (owned by and cascaded by a System Supplier)

Primary FoA reports owned by a System Supplier are listed on the PV-Mark certificate. The revision status of each FoA can be verified on the BMTV website under each System Supplier's certification entry. They are either used in isolation or can be used in conjunction with an appropriate associated document that is listed below, providing that the FoA report allows it and that both documents are compatible with each other. Where more than one primary FoA is listed for the same doorset type, they cannot be mix and matched, only one FoA is to be chosen and followed precisely.

FoA Report	System Supplier owner of Assessment Report	Doorset Description	Rating	Test Type
	NA			

Test Reports

Test reports are listed on the PV-Mark certificate. They cannot be used in conjunction with any primary FoA reports, test reports or associated documents. They must be followed precisely without any deviation whatsoever.

No specification or parameter changes are allowed at all from that stated within the test report such as size, shape, design, glazing, leaf/frame specification, hardware etc.

Test Report	Owner of Test Report	Doorset Description	Rating	Test Type
372762 B	Ideal Special Products FZC	IDEAL- Single Door – 60 (Doorset B) Unglazed (Opening away from fire only)	60min	BS 476: Part 22
372754	Ideal Special Products FZC	IDEAL- Double Door – 90 With Vision Panel (Opening away from fire only)	90min	BS 476: Part 22
372762 A	Ideal Special Products FZC	IDEAL- Single Door – 120 (Doorset A) with Vision Panel (Opening away from fire only)	120min	BS 476: Part 22
BMT/FEP/F14307 Rev. A	Ideal Special Products FZC	IDEAL- Double Door – 120 (Doorset A) Unglazed (Opening away from fire only)	120min	BS 476: Part 22
		IDEAL- Single Door – 120 (Doorset B) Unglazed (Opening away from fire only)	120min	